





ADDENDUM No. 2

| | | | |
|--------------|--|-------|-------------------|
| RFP NUMBER: | LRT-10-142-SPWS | | |
| RFP TITLE: | PASSENGER STATION POWER WASHING SERVICES | | |
| ADDENDUM NO: | 2 | DATE: | November 23, 2009 |

CLARIFICATIONS / CORRECTIONS

The following clarifications and/or corrections are hereby made part of and subject to the Request for Proposals:

| Item | Section/Article & Paragraph | Page(s) | Clarifications and/or Corrections | | | | | | | | | | | | | | | | |
|--------------------------------|--------------------------------|---------|---|------------------|------------------|----------------|----------------|-------------|-------------|---------------------------|---------------------------|--------------------------------|--------------------------------|-----|--------|----------|----------|---------------------|---------------------|
| REQUEST FOR PROPOSALS | | | | | | | | | | | | | | | | | | | |
| 1 | Addendum No. 1: Exhibit A | 1 | <div style="display: flex; justify-content: space-around;">   </div> <table border="1" style="margin-left: auto; margin-right: auto;"> <thead> <tr> <th>Station Location</th> <th>Station Location</th> </tr> </thead> <tbody> <tr> <td>19th/Camelback</td> <td>19th/Camelback</td> </tr> <tr> <th>Art Element</th> <th>Art Element</th> </tr> <tr> <td>Welded Aluminum Sculpture</td> <td>Welded Aluminum Sculpture</td> </tr> <tr> <th>Low Pressure Power Wash 300psi</th> <th>Low Pressure Power Wash 300psi</th> </tr> <tr> <td>yes</td> <td>Yes NO</td> </tr> <tr> <th>Schedule</th> <th>Schedule</th> </tr> <tr> <td>6, 12, 18, 24 weeks</td> <td>6, 12, 18, 24 weeks</td> </tr> </tbody> </table> <p>Welded Aluminum Sculpture at 19th/ Camelback is not cleaned by awarded Power Washing Contractor.</p> | Station Location | Station Location | 19th/Camelback | 19th/Camelback | Art Element | Art Element | Welded Aluminum Sculpture | Welded Aluminum Sculpture | Low Pressure Power Wash 300psi | Low Pressure Power Wash 300psi | yes | Yes NO | Schedule | Schedule | 6, 12, 18, 24 weeks | 6, 12, 18, 24 weeks |
| Station Location | Station Location | | | | | | | | | | | | | | | | | | |
| 19th/Camelback | 19th/Camelback | | | | | | | | | | | | | | | | | | |
| Art Element | Art Element | | | | | | | | | | | | | | | | | | |
| Welded Aluminum Sculpture | Welded Aluminum Sculpture | | | | | | | | | | | | | | | | | | |
| Low Pressure Power Wash 300psi | Low Pressure Power Wash 300psi | | | | | | | | | | | | | | | | | | |
| yes | Yes NO | | | | | | | | | | | | | | | | | | |
| Schedule | Schedule | | | | | | | | | | | | | | | | | | |
| 6, 12, 18, 24 weeks | 6, 12, 18, 24 weeks | | | | | | | | | | | | | | | | | | |

NOTE: Omitted text in RFP Addendum documents is denoted by ~~strikethrough~~. Added text in RFP Addendum documents is denoted by double underline. All changes to text in RFP Addendum denoted by outside border mark at side of changed paragraph.



ADDENDUM No. 2


LIST OF QUESTIONS AND VMR RESPONSE(S)

The following questions and VMR Responses are hereby made a part of and subject to the Request for Proposals.

| Item | Questions / Answers | |
|------|---------------------|---|
| 1 | Q | Here are the list of platforms where definition of platforms is questionable. Attachment A, pg. 2, section 3.2 – power washing area will be delineated by starting of handrail to end of handrail, on top of platform, above guide way tracks, but below overhead high-voltage lines |
| | A | All block pavers at passenger stations will be power washed, except the pavers located in emergency exit refuge area. Concrete sidewalk areas, located at street level, don't require power washing. |
| 2 | Q | Price/Apache – there is a walkway of about 15 ft. on both sides of platform before handrails begin. Is this walkway also considered part of platform? |
| | A | Yes, if block pavers are on deck. |
| 3 | Q | Rural/University – there are planters a few feet behind steel louvers on both sides of platform and walkways behind these planters, but no handrails. Is the walkway behind the planters also considered part of the platform? |
| | A | Yes, if block pavers are on deck. |
| 4 | Q | 3 rd Street/Washington – this platform has a public sidewalk included in the platform, is the platform only from the steel louvers to the tracks or is the complete sidewalk considered the platform? |
| | A | Yes, all block pavers should be included. |
| 5 | Q | Van Buren/Central and Van Buren/1 st Ave. – platforms have guard rail a few feet behind steel louvers. Is the walkway behind these guardrails also considered part of the platform? |
| | A | Yes, if block pavers are on deck. |
| 6 | Q | Roosevelt/Central North and Roosevelt/Central South – this V-shaped platform has a space between each platform heading north and south, is this space in between both platforms also part of the platforms or is the platform considered only from the beginning of the steel louvers towards the tracks? |
| | A | Per Addendum No. 1, all block pavers. Since these block pavers join both stations, the space between platforms requires power washing too. |








ADDENDUM No. 2

| Item | Questions / Answers | |
|------|---------------------|--|
| 7 | Q | Camelback/Central – there are concrete barriers of pillars leading a walkway towards platform, is this walkway also considered part of the platform? |
| | A | The post-lighted walkway going east, which is beyond platform, is part of the City of Phoenix (COP) transit center and is not included in the scope of services. |
| 8 | Q | Refuge areas on single entry platforms, are the refuge areas also considered part platforms? |
| | A | Per Addendum No. 1, refuge areas don't require power washing |
| 9 | Q | 19 th Ave./Camelback – the piece of art mentioned at this platform is actually located on the corner street of the park and ride across the street from platform. Is this piece of art still to be cleaned as part of platform? |
| | A | No.  Welded Aluminum Sculpture |

ATTACHMENTS:

- RFP Exhibit A revised page 1 (19th/Camelback)

END OF ADDENDUM NO. 2

| METRO PUBLIC ART: POWER WASHING SCHEDULE | | | | |
|---|---|--|---|---|
|  |  |  |  |  |
| Station Location | Station Location | Station Location | Station Location | Station Location |
| 19th/Montebello | 19th/Camelback | 7th/Camelback | Central/Camelback | Central/Camelback |
| Art Element | Art Element | Art Element | Art Element | Art Element |
| Perforated Metal Screens above canopy | Welded Aluminum Sculpture | Terrazzo Tile with non-skid coating | Granite Ring | Granite troughs |
| Low Pressure Power Wash 300psi | Low Pressure Power Wash 300psi | Low Pressure Power Wash 300psi | Low Pressure Power Wash 300psi | Low Pressure Power Wash 300psi |
| yes | yes NO | yes | yes | yes |
| Schedule | Schedule | Schedule | Schedule | Schedule |
| 6, 12, 18, 24 weeks | 6, 12, 18, 24 weeks | 4, 8, 12, 16, 18, 22 weeks | 6, 12, 18, 24 weeks | 6, 12, 18, 24 weeks |
| | <u>Welded Aluminum Sculpture at 19th/ Camelback is not cleaned by awarded Power Washing Contractor.</u> | Specific Instructions - Spray at minimum distance of 12". | | Specific Instructions - Do not clean corten steel supports |
| | | Sealant - Epoxy Polyaspartic | | |